



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA173026

Certificate Holder: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd, New & High Technology
Industrial Development Zone,
Hefei 230088,
P.R. China

Class Description: Non-Declared
Product Description: Grid-connected Inverter
Brand Name: SUNGROW
Model No.: SG3K-S
Markings: Input: 600Vdc Max,
MPP voltage range 90-560Vdc 10A I_{sc} PV 12A
Output: 230V~ 50Hz 13.7A 3kVA
Class I, IP65

Standard: IEC 62109-1 Ed. 1.0
IEC 62109-2 Ed. 1.0
AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: SAA173026 or RCM

Date First Registered: 4 December 2017

Date of Expiry: 4 December 2022

A handwritten signature in black ink, appearing to be 'JH', positioned above a horizontal line.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 04-12-17 173026/1



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA173026

Date of Issue: 4 December 2017

Class Description: Non-Declared

Product Description: Grid-connected Inverter

Additional Models

SG2K5-S

Description

Input: 600Vdc Max, MPP voltage range 90-560Vdc 10A I_{sc} PV 12A
Output: 230V~ 50Hz 11.3A 2.5kVA

SG2K-S

Input: 600Vdc Max, MPP voltage range 90-560Vdc 10A I_{sc} PV 12A
Output: 230V~ 50Hz 9.1A 2kVA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 04-12-17 173026/2