




ATTESTATION OF CONFORMITY

Issued to : Sungrow Power Supply Co., Ltd.
 : No.1699 Xiyou Rd., New & High Technology Industrial Development Zone,
 230088, Hefei, P. R. China

For the product : Grid-connected PV Inverter

Trademark : 

Type/Model : SG60KTL

Ratings : Class I;
 Input: MPPT voltage range: 570-850 Vdc, max 1000 Vdc, max 120 A;
 Output: 3N~, 400/230 V, 50/60 Hz, 60 kW, max 96 A

Manufactured by : Sungrow Power Supply Co., Ltd.
 : No.1699 Xiyou Rd., New & High Technology Industrial Development Zone,
 230088, Hefei, P. R. China

Requirements : EN 61000-3-12:2011
 IEC 61000-3-12:2011
 EN 61000-3-11:2000
 IEC 61000-3-11:2000

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6028518.50

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic compatibility directive 2014/30/EU.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 09 April 2018

Number: 6028518.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with



DEKRA Testing and Certification (Shanghai) Ltd.
 3F 250 Jiangchangsan Road Shibe Hi-Tech Park, 200436 Zhabei District, Shanghai, China
 T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com