

ATTESTATION OF CONFORMITY

Issued to : Sungrow Power Supply Co., Ltd.
: No.1699 Xiyou Rd., New & High Technology Industrial Development Zone,
230088, Hefei, P. R. China

For the product : Grid-connected PV Inverter

Trademark : 

Type/Model : SG125HV

Ratings : DC Input:
: MPPT voltage range: 860-1450Vdc, max 1500Vdc, max 148A, Isc PV: 240A
AC Output:
600V 3~, 50Hz, rated 125kW, max 125kVA, max 120A

Manufactured by : Sungrow Power Supply Co., Ltd.
: No.1699 Xiyou Rd., New & High Technology Industrial Development Zone,
230088, Hefei, P. R. China

Requirements : IEC 61683:1999

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6029690.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 15 May 2018

Number: 6029690.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed.