


# ATTESTATION OF CONFORMITY

Issued to: Sungrow Power Supply Co., Ltd.  
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,  
Hefei, P. R. China

For the product: Grid-Connected PV Inverter

Trade name: 

Type/Model: SG80KTL, SG80KTL-20

Ratings: DC input: max 1100Vdc, MPP voltage range: 570-850Vdc, max 144A, Isc PV: 200A  
AC Output: 400 V, 3~, 50 Hz, rated 80 kW, max 80 kVA, max 116 A, power factor  
range: [-0,8...+0,8]

Manufactured by: Sungrow Power Supply Co., Ltd.  
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,  
Hefei, P. R. China

Requirements: NRS 097-2-1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6035428.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.  
The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 11 July 2018

Number: 6035428.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

  
Kreny Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed