



Product Service

Attestation of Conformity

No. E8A 16 11 73342 144

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**No. 1699 Xiyou Road, New & High
Technology Industrial Development Zone,
230088 Hefei, Anhui
PEOPLE'S REPUBLIC OF CHINA**Name of Object:** **Converter
PV Grid Connected Inverter****Model(s):** **SG2KTL-S, SG2K5TL-S, SG3KTL-S, SG3KTL-D,
SG3K6TL-D, SG4KTL-D, SG4K6TL-D, SG5KTL-D****Description of
Object:**

| | |
|-----------------------|---|
| Input voltage: | DC 110V~600V |
| Max. input power: | 3KW, 3.3KW, 4KW, 4KW, 4.7KW, 5.2KW, 6.0KW, 6.5KW |
| Rated output voltage: | AC 230V |
| Rated frequency: | 50Hz |
| Rated output power: | 2KW, 2.5KW, 3KW, 3KW, 3.6KW, 4KW, 4.6KW, 5KW |
| Protection class: | I |

**Tested
according to:** EN 61000-6-2:2005
EN 61000-6-3:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 4842016258700*Jun Bao***Date,** 2016-11-08 (Jun Bao)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1