

ATTESTATION OF CONFORMITY

Issued to: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

For the product: Grid-connected PV inverter

Trade name: **SUNGROW**

Type/Model: SG36KTL-M

Ratings: IP65, Class I;
Input: MPPT voltage range: 200-950 Vdc, max 1100 Vdc, max 88 A;
Output: 3N~, 400 V, 50 Hz, 36 kW, max 53 A

Manufactured by: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

Requirements: Engineering Recommendation G59 Issue 3 Amendment 2: 2015
(G59/3-2)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 3194194.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 31 August 2016

Number: 3194194.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

C. Lin
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 8

DEKRA Testing and Certification (Shanghai) Ltd.

3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com